



**Government of West Bengal**  
**Office of the Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**  
**Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101**

Memo No.: FSR/Dy.DFS/1411/2013

Date : 06-06-2024

**From :**  
Divisional Fire Officer  
Purulia Division,  
West Bengal Fire & Emergency Services

**To :**  
BKM Educational Society ( BKM College of Education).  
Vill. Lachhia, P.O Ramkanali, P.S Raghunathpur, Dist. Pirulia, Pin 723142.

**Sub : Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational Occupancy in favour of the BKM Educational Society in the name and style as "BKM COLLEGE OF EDUCATION" situated at Vill-Lachhia, PO-Ramkanali, Mouza-Lachhia, Plot No-574, 575(P), Kh No-03, JL No-168 under Lachhia GP, PS-Raghunathpur, Dist-Purulia, Pin-723142(W.B)**

This is in reference to your AIN 211912406300000692 dated 28-May-2024 regarding Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational Occupancy in favour of the BKM Educational Society in the name and style as "BKM COLLEGE OF EDUCATION" situated at Vill-Lachhia, PO-Ramkanali, Mouza-Lachhia, Plot No-574, 575(P), Kh No-03, JL No-168 under Lachhia GP, PS-Raghunathpur, Dist-Purulia, Pin-723142(W.B).

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

**However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.**

**Recommendation:**



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000692

1. All the Fire Safety measures provided in the building must be kept in good working Condition all the time to ensure fire & life safety of the building.
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
3. The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Buildings shall be strictly maintained.
5. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
6. A Fire control room including a closed-circuit TV system shall have to be maintained which Observe all the floors of the building.
7. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
8. The teaching, nonteaching & security staff shall be conversant with installed firefighting Equipment of the buildings and to operate in the event of fire and testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
10. A trained Fireman shall be maintained round the clock for fire safety of the building.
11. First Aid firefighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all The Fire Fighting installation in the buildings to keep them in perfectly good working Condition at all the time. 13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.
14. Electrical Ducts shall have to be sealed vertically and horizontally in proper manner Immediately.
15. The Renewal of Fire Safety Certificate is valid for a period of three years and has to be renewed within stipulated period from the date of issuance of this certificate from the Director General, West Bengal Fire & Emergency Services regarding the satisfactory services, performance of all the Life and Fire Safety arrangements and installations of the building.
16. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, the Renewal of Fire Safety Certificate will be treated as cancelled.

Valid Upto : 05-Jun-2027

Memo No.: FSR/Dy.DFS/1411/2013



**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000692